



NOTES:

1. ALL PIPE AND FITTINGS SHALL BE THREADED BRASS.
2. DIELECTRIC FITTINGS SHALL BE USED AT THE CONNECTION OF ANY BRASS PIPE, VALVE OR FITTING TO THE CAST IRON AIR RELEASE VALVE.
3. SECURE STAINLESS STEEL SUPPORT BASE PLATES TO FLOOR WITH 1/4" STAINLESS STEEL EPOXY ANCHORS.
4. ADDITIONAL PIPE SUPPORTS MAY BE REQUIRED FOR PIPES LARGER THAN 2".
5. ALL CONCRETE SURFACES TO HAVE MANHOLE INTERIOR COATING.
6. CABLE SHALL BE OF SUFFICIENT LENGTH TO ALLOW THE ODOR CONTROL UNIT TO BE PLACED ON THE SURROUNDING SURFACE WITHOUT THE NEED TO DISCONNECT THE CLAMP.



**Snyder Basin Water
Reclamation District**

**LOW-PRESSURE
COMBINATION AIR VALVE**

STANDARD DETAIL

LP-03

Revision Date: 4/20/20