



NOTE:

1. WHERE AN EXTERNAL CHECK VALVE IS REQUIRED BY THE PUMP MANUFACTURER, THE PRESSURE LINE TEST TEE MUST BE LOCATED BETWEEN THE CHECK VALVE AND THE PUMP STATION.



**Snyderville Basin Water
Reclamation District**

**TYPICAL EXTERIOR PUMP
STATION INSTALLATION**

STANDARD DETAIL

LAT-09

Revision Date: 4/20/20