



NOTES:

1. WHERE AN EXTERNAL CHECK VALVE IS REQUIRED BY THE PUMP MANUFACTURER, THE PRESSURE LINE TEST TEE MUST BE LOCATED BETWEEN THE CHECK VALVE AND THE PUMP STATION.
2. 7' MINIMUM COVER FOR PRESSURE LATERALS LOCATED UNDER AREAS THAT MAY BE CLEARED OF SNOW AND HAVE VEHICULAR TRAFFIC.



**Snyder Basin Water
Reclamation District**

**TYPICAL EXTERIOR PUMP
STATION INSTALLATION**

STANDARD DETAIL

LAT-09

Revision Date: 11/9/20